3500/77M Recip Cylinder Pressure Monitor





Description

The 3500/77M Recip Cylinder Pressure Monitor is a 4-channel monitor that accepts input from Bently Nevada approved pressure transducers, conditions the signal to make various reciprocating compressor cylinder pressure measurements, and compares the conditioned signals with user-programmable alarms.

The primary purpose of the 3500/77M monitor is to provide:

- Machinery protection by continuously comparing monitored parameters against configured alarm setpoints to drive alarms.
- Essential machine information for both operations and maintenance personnel.

Each channel, depending on configuration, typically conditions its input signal into various parameters called "proportional values," also referred to as PPL's. Alert setpoints can be configured for each active proportional value (PPL) and danger setpoints can be configured for any two of the active proportional values.

Each channel of the 3500/77M will provide eight PPL values that relate to cylinder pressure operation. Five PPL values relate to a single chamber and are as follows:

- Discharge Pressure
- Suction Pressure
- Maximum Pressure
- Minimum Pressure
- Compression Ratio
- Three PPL values use one or more channel's values in combination with configured mechanical parameters to compute their value:
 - Peak Rod Compression
 - Peak Rod Tension
 - Degree of Rod Reversal



Specifications

Inputs

Signal:

Accepts from 1 to 4 channels of Bently approved positive voltage third party pressure transducers (psia)

Power

Consumption

Outputs

OK LED

TX/RX LED

Bypass LED

Buffered Transducer Outputs

Front Panel LEDs

7.8 Watts, transducer supplies at full

Indicates when the 3500/77M is

Indicates when the 3500/77M is

communicating with other modules in

Indicates when the 3500/77M is in

The front of each monitor has one coaxial connector for each channel. Each connector is short-circuit

Note: The Buffered Transducer Outputs on

monitors using the Cylinder Pressure I/O module

operating properly.

the 3500 rack.

Bypass Mode.

protected.

load.

Scale Factor

95,000 µV/psi for 100 psia range* 38,000 µV/psi for 250 psia range* 19,000 µV/psi for 500 psia range* 9,500 µV/psi for 1000 psia range* 3,800 µV/psi for 2500 psia range* 1,900 µV/psi for 5000 psia range* 950 µV/psi for 10000 psia range*

*All pressure transducers will be supplied with scale factor specifications that include pressure/voltage values at two points. The above data assumes +0.5 Vdc at 0 psia and +10.0 Vdc at full-range.

will be inverted and offset by -2.265 Vdc. Signal Conditioning **Output Impedance** Frequency 550 Ω Response Transducer Power 0 to 5.5 kHz on all configured Supply pressure channels $+23.0 \pm 0.8$ Vdc with 24.5ma current Pressure limiting on each channel. Accuracy **Environmental Limits** Within \pm 0.5% of pressure transducer full-range (9.5 volts: From +0.5 to **Operating Temperature** +10.0 volts) @ +25°C When used with Internal/External Within \pm 1.0% of pressure transducer Termination Cylinder full-range (9.5 volts: From +0.5 to Pressure I/O Module: +10.0 volts) over -30°C to +65°C -30°C to +65°C (-22°F to +150°F) **Proportional Values** Storage **Cylinder Pressure** Temperature Discharge Pressure, Suction -40°C to +85°C (-40°F to +185°F) Pressure, Maximum Pressure, Humidity Minimum Pressure, Compression 95%, non-condensing Ratio, Peak Rod Compression, Peak Rod Tension, Degree of Rod **CE Mark Directives** Reversal **EMC Directives** Input Impedance EN50081-2 Internal/ External Radiated Termination Emissions **Cvlinder Pressure** EN 55011, Class A 1/0: Conducted

 $50 \text{ k}\Omega$

Emissions


EN 55011, Class A

EN50082-2 Electrostatic Discharge		Rack Space Requirements Monitor Module			
Discharge	EN 61000-4-2, Criteria B	Wonter Weddie	1 full-h	eight front slot	
Radiated Susceptibility	ENV 50140, Criteria A	I/O Modules 1 full-height rear slot			
Conducted					
Susceptibility		Ordering Infor	rmati	on	
	ENV 50141, Criteria A	Ordering Consid	ering Considerations		
Electrical Fast Transient		General			
	EN 61000-4-4, Criteria B		The 3500/77M Module requires the following (or later) firmware, and software revisions:		
Surge Capability Magnetic Field		 3500/77M Modu 	dule Firmware – Revision L		
	EN 61000-4-5, Criteria B	 3500/01 Software – Version 3.00 3500/02 Software – Version 2.30 			
	EN 61000-4-8, Criteria A	 3500/03 Software – Version 1.30 			
Power Supply Dip		External Termination Blocks cannot be used with Internal Termination I/O Modules.			
r	EN 61000-4-11, Criteria B	When ordering I/O Modules with External Terminations, the			
Radio		External Termination separately.	Blocks	and Cables must be ordered	
Telephone					
	ENV 50204, Criteria B	List of Options and			
Low Voltage		Cylinder Pressure			
Directives EN 61010-1		3500/77M-AXX-BXX			
	Safety Requirements	A: I/O Module Type	e 03	Cylinder Pressure I/O with	
Hazardous Area	Approvals		05	Internal Terminations.	
CSA/NRTL/C			04	Cylinder Pressure I/O with	
	When used with Internal/External			External Terminations	
	Termination I/O Module: Class I, Division 2, Groups A through D	B: Agency Approval	Option		
	,,		00	None	
Physical Maritan Markula			01	CSA/NRTL/C	
Monitor Module Dimensions (Height x Width x Depth)		External			
		Termination Blocks 125808-10	i		
	241.3 mm x 24.4 mm x 241.8 mm	120000-10	Cylind	er Pressure External Terminatio	
	(9.50 in x 0.96 in x 9.52 in)			(Euro Style connectors).	
Weight	0.91 kg (2.0 lbs.)	128015-10			
VO Madulaa	0.01 NY (2.0 IDS.)			er Pressure External Terminatio	
I/O Modules Dimensions (Height			Block (Terminal Strip connectors).		
x Width x Depth)			3500 Transducer Signal to External Termination Block		
	241.3 mm x 24.4 mm x 99.1 mm	Cable	v		
	(9.50 in x 0.96 in x 3.90 in)	129525 -AXXXX-BX	^		
Weight	0.20 kg (0.44 lb.)	A: Cable Length	0005	5 5 feet (1.5 metres)	
	ט.20 אין נט.די וט.)			· · · ·	
			0007	()	
			0010	 10 feet (3 metres) 	

	0 0 2 5 25 feet (7.5 metres)
	0 0 5 0 50 feet (15 metres)
	0 1 0 0 100 feet (30.5 metres)
B: Assembly Ins	structions
, , , , , , , , , , , , , , , , , , ,	01 Not Assembled
	02 Assembled
SPARES	
146282-01	
	3500/77M Monitor Manual.
140734-07	
	3500/77M Cylinder Pressure Monitor.
143729-01	Ordinadas Desessor VO Marketa III
	Cylinder Pressure I/O Module with Internal Terminations for Bently
	Approved Third Party Pressure
	Transducers.
143737-01	
	Cylinder Pressure I/O Module with External Terminations for Bently
	Approved Third Party Pressure
	Transducers.
00580434	
	Internal I/O Module connector
	header, Euro Style, 8 pin. Used on I/O modules 143729-01.
00580441	
00000111	Internal I/O Module connector
	header, Euro Style, 3 pin. Used on
	I/O modules 143729-01.
146973-01	Recip Multi-Event Wheel Kit.
115700 04	
145732-01	Recip Multi-Event Wheel.
146622-01	
140022-01	Recip Multi-Event Wheel Stud.
165855-XX	
100000 701	Recip Cylinder Pressure Transducer.
	(See 165855 data sheet)

© 2004 Bently Nevada LLC ® used in this document are registered marks of Bently Nevada, LLC.

Front and Rear View



- (1) Main 3500/77M Cylinder Pressure Monitor Module (front view).
- (2) Status LEDs.
- (3) Buffered transducer outputs. These provide an unfiltered output for each of the four transducers. All are short circuit protected.
- (4) I/O module rear views.
- (5) Cylinder Pressure I/O Module, Internal Termination.
- (6) Cylinder Pressure I/O Module, External Termination.